



AMENDED

ASBESTOS LABORATORY REPORT

Prepared for

Anderson Property Inspections

PROJECT: 841 E. Monument St.

CEI LAB CODE: A14-12080

DATE ANALYZED: 08/29/14

DATE REPORTED: 09/02/14

TOTAL SAMPLES ANALYZED: 5

SAMPLES >1% ASBESTOS:

TEL: 866-481-1412

www.ceilabs.com



AMENDED

Asbestos Report Summary

By: POLARIZING LIGHT MICROSCOPY

PROJECT: 841 E. Monument St.

CEI LAB CODE: A14-12080

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

Client ID	Layer	Lab ID	Color	Sample Description	ASBESTOS %
A841 1		A1807255	Brown,White	Fiberboard W/ Compound	None Detected
A841 2		A1807256	White,Brown	Fiberboard W/ Compound	None Detected
A841 3		A1807257	White,Brown	Fiberboard W/ Compound	None Detected
B841 1		A1807258	Tan	Mastic W/ Fiberboard	None Detected
C841 1		A1807259	White,Tan	Sealant Assoc W/ Tub	None Detected



AMENDED

ASBESTOS BULK ANALYSIS

By: POLARIZING LIGHT MICROSCOPY

Client: Anderson Property Inspections
115 Del Oro Circle
Colorado Springs, CO 80919

CEI Lab Code: A14-12080
Date Received: 08-28-14
Date Analyzed: 08-29-14
Date Reported: 09-02-14

Project: 841 E. Monument St.

ASBESTOS BULK PLM, EPA 600 METHOD

Client ID Lab ID	Lab Description	Lab Attributes	NON-ASBESTOS COMPONENTS				ASBESTOS %
			Fibrous		Non-Fibrous		
A841 1 A1807255	Fiberboard W/ Compound	Heterogeneous Brown,White Fibrous Bound	70%	Cellulose	20%	Tar Paint Binder	None Detected
A841 2 A1807256	Fiberboard W/ Compound	Homogeneous White,Brown Fibrous Bound	70%	Cellulose	20%	Tar Paint	None Detected
A841 3 A1807257	Fiberboard W/ Compound	Homogeneous White,Brown Fibrous Bound	90%	Cellulose	5%	Paint Binder	None Detected
B841 1 A1807258	Mastic W/ Fiberboard	Homogeneous Tan Fibrous Bound	60%	Cellulose	20%	Tar Paint Binder	None Detected
C841 1 A1807259	Sealant Assoc W/ Tub	Homogeneous White,Tan Fibrous Bound	50%	Cellulose	40%	Binder Paint	None Detected



AMENDED

LEGEND: Non-Anth = Non-Asbestiform Anthophyllite
Non-Trem = Non-Asbestiform Tremolite
Calc Carb = Calcium Carbonate

METHOD: EPA 600 / R93 / 116 and EPA 600 / M4-82 / 020

The detection limit for the method is <1% by visual estimation and 0.25% by 400 point counts or 0.1% by 1,000 point counts.

Due to the limitations of the EPA 600 Method, nonfriable organically bound materials (NOBs) such as vinyl floor tiles can be difficult to analyze via polarizing light microscopy (PLM). EPA recommends that all NOBs analyzed by PLM, and found not to contain asbestos, be further analyzed by Transmission Electron Microscopy (TEM). Please note that PLM analysis of dust and soil samples for asbestos is not covered under NVLAP accreditation.

CEI Labs, Inc. can perform positive stop analysis if requested by customer. However, it is the responsibility of the customer to determine if the samples grouped together are in fact the same type of material and belong to the same homogeneous area.

This report may not be reproduced, except in full, without written approval by CEI LABS. CEI LABS makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U. S. Government.

ANALYST: *Sarah Talley*
Sarah Talley

APPROVED BY: *Tianbao Bai*
Tianbao Bai, Ph.D.
Laboratory Director





107 New Edition Court, Cary, NC 27511
 Tel: 866-481-1412; Fax: 919-481-1442

ASBESTOS CHAIN OF CUSTODY

LAB USE ONLY:
CEI Lab Code:
CEI Lab I.D. Range:

COMPANY INFORMATION	PROJECT INFORMATION
CEI CLIENT #:	Job Contact:
Company: Anderson Property Inspections	Email / Tel:
Address: 115 Del Oro Circle	Project Name:
Colorado Springs, CO 80919	Project ID# 841 E. MINNIMENT ST.
Email: coloradospringsinspectors@gmail.com	PO #:
Tel: 719-640-8489 Fax:	STATE SAMPLES COLLECTED IN: Colorado

GENERAL INSTRUCTIONS		
POSITIVE STOP ANALYSIS	<input checked="" type="checkbox"/>	PLM DUE DATE: / /
ANALYZE NOB'S BY TEM	<input type="checkbox"/>	TEM DUE DATE: / /

IF TAT IS NOT MARKED STANDARD 3 DAY TAT APPLIES.

ASBESTOS	METHOD	TURN AROUND TIME					
		4 HR	8 HR	24 HR	2 DAY	3 DAY	5 DAY
PLM BULK	EPA 600	<input checked="" type="checkbox"/>	<input type="checkbox"/>				
PLM POINT COUNT (400)	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM POINT COUNT (1000)	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PLM GRAV w POINT COUNT	EPA 600	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PCM AIR	NIOSH 7400	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR AHERA	EPA AHERA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM AIR NIOSH	NIOSH 7402	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM BULK	CHATFIELD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM DUST WIPE	ASTM D6480-05	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM DUST MICROVAC	ASTM D5755-09	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM SOIL	ASTM D7521-13	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
TEM VERMICULITE	CINCINNATI METHOD	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER:		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

REMARKS:		<input type="checkbox"/> Accept Samples	<input type="checkbox"/> Reject Samples
Relinquished By:	Date/Time	Received By:	Date/Time
<i>[Signature]</i>	9/9/14		

Samples will be disposed of 30 days after analysis

