

ADDENDUM NUMBER : 1

Page 1 of 1

Date: February 9, 2015

The Housing Development Division of the City of Colorado Springs

Owners: Lucille Rudolph

RFQ Closing Date: February 17, 2015, 1pm

Address: 922 Boggs Pl

Quote No.: 14-094 RO

This document shall become as fully a part of the above named Contract Documents as if included and shall take full and complete precedence over anything stated or shown to the contrary in them.

Each and every respondent, subcontractor and material supplier shall be responsible for reading each and every item in this Addendum to ascertain the extent and manner it affects the work in which he/she is interested.

Acknowledge receipt of Addendum on the Request for Quote and indicate any changes in the base proposal. **The contractor is directed to make the following changes to the work description for the above referenced property:**

WD ITEM # 4 - Window Replacement - Window Sills: Provide and install 5 1/4" beige engineered marble window sills by Manstone (719) 578-1500 or equivalent upon window replacement. Match existing square design, no dog ear cut / wrap outside of sill necessary. Include sill replacement in window quote.

Item # 4 Revised Total \$ _____

WD ITEM #7 - Aluminum Ramp - Potential Hose Spigot Conflict: Ramp may require modification of front hose spigot. Include re-configuration of spigot in ramp quote by providing and installing a 90 degree elbow, extension piece, and new top operated valve control, versus front.

Item # 7 Revised Total \$ _____

WD ITEM #18 - Toilet Installation - Wall Cabinet: Installation of right height toilet in conflict with current over toilet organizer. Replace over toilet organizer with wall cabinet. Provide and install cabinet above toilet to accommodate homeowner's height and reach. Homeowner to approve style, size, and placement of cabinet. Include wall cabinet in toilet installation quote.

Item # 18 Revised Total \$ _____

WD ITEM #25 Appliances and #26 Wall Cabinet - Microhood and Cabinet Modification: Remove the microhood from the appliance total(subtract \$400 off of allowance), and remove the upper wall cabinet modification from the work description.

Item # 25 Revised Total \$ _____

NEW WD ITEM #30 Garage Weather Stripping: Provide and install weather stripping to bottom of garage door to completely seal air and water infiltration.

Item # 30 Total \$ _____

Lucille Rudolph: _____

Date: _____

For City: Paul Morrow: _____

Date: _____

General Contractor: _____

Date: _____