

Drawing Revisions

Item No. 1.1.

DRAWING SHEET A-421

Add Add a 16"x16" ceiling access panel in both the men's and women's restrooms. Location of panels to be field verified in order to provide easy access to space above restrooms. Panel to be flush mounted and finished in white to match the ceiling. Basis-of-design to be J. L. Industries, Inc., PWE Access Panel (Plaster Ceiling Wall Panel). Follow manufacturer recommendations for installation.

Contractor to provide submittals of product data and shop drawings during construction, prior to purchasing.

Item No. 1.2.

DRAWING SHEET A-410 and A-411

Revise Revise all non-ADA restroom partitions doors to have 32 inches clear width.

Add Add grab bars to one water closet partition in each of the Men's and Women's restrooms.

Item No. 1.3.

DRAWING SHEET P-101

Add Water pipe sizing table

Item No. 1.4.

DRAWING SHEET E100

Add Requirements to field verify existing electrical circuits during construction. Keynote #1 has been revised, keynote #11 added.

Remove Keynote #2

Revise Electrical code requirements changed from 2012 IECC to 2009 IECC per building code officials request.

Contractor Questions:

Item No. 3.1.

QUESTION:

Underneath the southeast corner of the women's restroom is a large duct not identified on the drawings. The floor will be lowered in this location and there could be potential conflict between the toilet drains and the existing duct. Is the duct being altered or the drains rerouted to avoid this conflict with the duct?

RESPONSE:

Due to the location and type of the new plumbing fixtures, the route of the drains below cannot be altered. The existing drawings do not show this section of ductwork. Contractor to field verify source of ductwork and if this section can be moved to accommodate the plumbing fixture drains from above. Assume that this section of duct work will require relocation to accommodate the new drains and floor location elevation.

END OF ADDENDUM #2